

O/C

CIN No. : L26943RJ1979PLC001935
Phone : 01462 228101-6
Toll Free : 1800 180 6003 / 6004
Fax : 01462 228117 / 228119
E-Mail : shreebwr@shreecementltd.com
Website : www.shreecement.in



SHREE CEMENT LTD.

Regd. Office:

BANGUR NAGAR, POST BOX NO.33, BEAWAR 305 901, RAJASTHAN, INDIA



SCL/RAS/ CPP /Env. Statement/2016-17/

8528

Date: 20/09/2016

To,

File No. P-120

The Member Secretary,
Rajasthan Pollution Control Board,
4, Institutional Area, Jhalana Doongri Road,
JAIPUR-302004 (Rajasthan).

Sub:- Environmental Statement for the period from April 2015 to March 2016 for 238 MW Power Plant (160 MW Thermal Power Generation & 78 MW Waste Heat Power Generation) including 1000 KVA D.G. Set of M/s Shree Cement Limited situated at Village- Ras Bhingarh, Tehsil- Jaitaran, Dist- Pali (Raj).

Ref: - CTO No. - F (Tech)/ Pali (Jaitaran)/ 2 (1)/ 2008-2009/6382-6385 dated: 27/11/2014
F. (CPM) / Pali (Jaitaran) / 1024 (1) / 2013-2014 / 7087-7089 dated 22/01/2016.

Sir,

We are submitting herewith the Environmental Statement for the period from April 2015 to March 2016 for 238 MW Power Plant (160 MW Thermal Power Generation & 78 MW Waste Heat Power Generation) including 1000 KVA D.G. Set of M/s Shree Cement Limited situated at Village- Ras Bhingarh, Tehsil- Jaitaran, Dist- Pali (Raj)

This is for your kind information please.

Thanking you,
Yours faithfully,

For Shree Cement Ltd;

Rakesh Bhargava

(Rakesh Bhargava)
Vice President (Environment)

Copy to:-

1. Chief Conservator of Forests (Central), Ministry of Environment & Forests, Central Regional Office, Kendriya Bhawan, 5th Floor Sector H, Aliganj, Lucknow – 226024 (U.P.)
2. The Regional Officer (Regional Office), Rajasthan Board for the Prevention & Control of Pollution, S / A-6, Mandia Road, Industrial Area, Near Pali Urban Co-Operative Bank, PALI-MARWAR- 306401 (Raj.)

O/C - Environment Dept. Ras

JAIPUR OFFICE : SB-187, Bapu Nagar, Opp. Rajasthan University, JLN Marg, Jaipur-302 015

Phone : 0141 4241200, 4241204, Fax : 0141 4241219

NEW DELHI OFFICE : 122-123, Hans Bhawan, 1, Bhadurshah Zafar Marg, New Delhi 110 002

Phone : 011 23370828, 23379218, 23370776, Fax : 011 23370499

CORP. OFFICE : 21, Strand Road, Kolkata 700 001 Phone : 033-22309601-4 Fax : 033 22434226

ENVIRONMENTAL STATEMENT
M/s Shree Cement Limited
Captive Power Plant Including D.G. Set
Period from : April, 2015 to : March, 2016

FORM – V

PART – A

1.	Name and address of the Owner / Occupier of the Industry operation or process	Captive Power Plant M/S Shree Cement Ltd Village: Ras/Bhimgarh, Tehsil: Jaitaran, Dist:Pali - 306107 (Rajasthan)
2.	Industry Category Primary (S.T.C. Code) Secondary (S.T.C. Code)	Red Category
3.	Production Capacity	160MW Thermal Power generation 78 MW Waste Heat recovery based 1000 KVA D.G.
4.	Year of Establishment	Power Plant: 2007-2010 Waste Heat Power Plant: 2009-14 D.G. Set: 2006
5.	Date of the last Environmental Statement submitted	20/09/2015

PART – B

WATER AND RAW MATERIAL CONSUMPTION

(I) WATER CONSUMPTION:

Process & Cooling/ Construction : 269941 KL

Domestic : 71710 KL (Common for
Cement Plant & Power Plant)

Name of Product	Process Water Consumption per Unit of Product Output	
	During Previous Financial Year (2014-2015)	During Current Financial Year (2015-2016)
Power	0.000473 KL / KWH	0.000231 KL / KWH

(II) RAW MATERIAL CONSUMPTION:(Power Plant)

Name of Raw Material	Name of Product	Consumption of Raw Material Per Unit of Output (Power)	
		During Previous Financial year (2014-2015)	During Current Financial year (2015-2016)
1. Water	Power	0.000473 KL / KWH	0.000231 KL / KWH
2.Coal/ Petcoke		0.00038809 Metric ton / KWH	0.00025088 Metric ton / KWH

(III) RAW MATERIAL CONSUMPTION: (D.G. SET)

D.G. Set is not operated on continuous basis. D.G. Set is operated only during the breakdown/shutdown of Power Plant. The total fuel consumption during the year 2015-2016 was nil.

Name of Raw Material	Name of Product	Consumption of Raw Material per unit of Output (LTR / KWH)	
		During Previous Financial year (2014-2015)	During Current Financial year (2015-2016)
H.S. Diesel	Power	0.00	0.00

(IV) POWER CONSUMPTION (KWH/KWH OF POWER):

During Previous Financial Year (2014-2015)	During Current Financial Year (2015-2016)
0.0603	0.0637

(V) TOTAL POWER PRODUCTION (KWH):

During Previous Financial Year (2014-2015)	During Current Financial Year (2015-2016)
645498096	1170650131

(VI) TOTAL D.G. POWER PRODUCTION (KWH):

During Previous Financial Year (2014-2015)	During Current Financial Year (2015-2016)
0.00 KWH	0.00 KWH

PART – C

DISCHARGED TO ENVIRONMENTAL / UNIT OF OUTPUT

Pollutants	Quantity of Pollutants Discharged (Mass/Day)	Concentration of Pollutants in Discharge (Mass/Value)	Percentage of variation from prescribed standard with reasons
(a)	Water	<p>The waste water generated from the office toilet and mess is treated in STP and treated water is used in plantation.</p> <p>Analysis Report of STP treated water is attached as Annexure-4.</p> <p>During the year 2015-2016 total 53110 KL waste water was generated from the Power plant. The entire waste water generated from the power plant is used for the Synthetic Gypsum Manufacturing and ash quenching.</p>	
(b)	Air	Please refer Annexure – 2 & 3	

PART – D

HAZARDOUS WASTE

(As specified under Hazardous Wastes (Management, Handling & Trans boundary Movement Rule, 2016))

Hazardous Waste	Total Quantity (Ltrs.)	
	During Previous Financial Year (2014-2015)	During Current Financial Year (2015-2016)
a) From Process	<p>Common authorization for Hazardous Waste Management & Handling for Cement Plant, Power Plant, D.G.Set and Nimbeti Limestone Mines.</p> <p>Total Quantity generated from April-2014 to March-2015 = 18480 Ltrs. Old Stock = 2730 Ltrs. Total Used oil = 21210 Ltrs. Sold-out to registered recycler = 21210 Ltrs. Balance Quantity= 0 Ltrs</p>	<p>Common authorization for Hazardous Waste Management & Handling for Cement Plant, Power Plant, D.G.Set and Nimbeti Limestone Mines.</p> <p>Total Quantity generated from April-2015 to March-2016 = 22470 Ltrs. Old Stock = 0 Ltrs. Total Used oil = 22470 Ltrs. Sold-out to registered recycler = 22470 Ltrs. Balance Quantity= 0 Ltrs</p>
(b) From Pollution Control Facilities	N.A.	N.A.

PART – E
SOLID WASTE

		Total Quantity (Metric ton)	
		During Previous Financial Year (2014-15)	During Current Financial Year (2015-16)
(a)	From Process	Bed Ash : NIL	Bed Ash : Nil
(b)	From Pollution Control Facility	Fly Ash : 27802 Synthetic Gypsum : Nil	Fly Ash : 145 Synthetic Gypsum : 75846
(c)	1. Quantity rejected or re- utilized within the unit	Fly ash and Bed ash are generated from the power plant as a solid waste which are used in the cement manufacturing process of our existing cement plants	
	2. Sold	Nil	Nil
	3. Disposed	Nil	Nil

PART – F

Please specify the characterization (in terms of composition and quantum) of hazardous as well as solid wastes and indicate disposal practice adopted for both the categories of wastes:

Hazardous Wastes

No Hazardous waste is generated from the Unit except used oil which is drained from Machineries / Equipment. The used oil & Lead acid batteries are sold to CPCB authorized recyclers.

Bio-Medical Wastes:

Bio-medical waste generated is common for cement plant, power plant and mines during current financial year April 2015 to March 2016 under the Bio-Medical Waste (Management & Handling) Rules 2016, are as follows.

	Bio-Medical Waste Quantity (Kg) as per Colour Coding			
	Red (Cat 3 & 6)	Blue (Cat 4 & 7)	Yellow (Cat 1 & 2)	Black (Cat 5,9,10)
April 2015 to March 2016	25.38	38.7	47.41	26.05

Above mentioned waste has been sent to Sales Promoter, CBWTF Bio Medical Treatment Facility, Jaipur Bye Pass Road, Ajmer (Raj.) for disposal.

E- Wastes:

	Total Quantity	
	During Previous Financial Year (2014-15)	During Current Financial Year (2015-16)
From Process	850 Kg.	Nil
From Pollution Control Facility	Nil	Nil

Solid Wastes: - N.A.

Battery Wastes:

As specified under Batteries (Management and Handling) Amendment Rules, 2010, we have purchased following new batteries of different categories is common for cement plant, power plant and mines -

1	Number of new batteries of different categories purchased from the manufacturer / importer / dealer or any other agency	During 1 st Apr 2015 to 31 st Mar 2016	
	Category:	(i) No. of Batteries	(ii) Approximate Weight (In Metric Tonnes)
	(i) Automotive		
	a) Four wheeler	145	6.050
	b) Two wheeler	Nil	Nil
	(ii) Industrial		
	a) UPS	294	2.352
	b) Motive Power	Nil	Nil
	c) Stand –by	Nil	Nil
	(iii) Others	Nil	Nil
	Total	439 Nos	8.402 MT
2	Number of used batteries of categories mentioned in Sl. No 3 and Tonnage of scrap sent manufacturer/dealer/importer/registered recycler/or any other agency to whom the used batteries scrap was sent	During 1 st Apr 2015 to 31 st Mar 2016	
	Category:	(i) No. of Batteries	(ii) Approximate Weight (In Metric Tonnes)
	(i) Automotive		
	a) Four wheeler	128	6.738
	b) Two wheeler	Nil	Nil
	(ii) Industrial	Nil	Nil
	a) UPS	834	6.512
	b) Motive Power	Nil	Nil
	c) Stand –by	Nil	Nil
	(iii) Others	Nil	Nil
	Total	962 Nos.	13.25 MT

Used battery scrap was sent to CPCB authorized recycler

Solid Wastes:

Only Fly ash and Bed ash is generated from the power plant as a solid waste which is used in the cement manufacturing process of our existing cement plants.

PART – G

IMPACT OF THE POLLUTION CONTROL MEASURES ON CONSERVATION OF NATURAL RESOURCES AND CONSEQUENTLY ON THE COST OF PRODUCTION

Captive Power Plant is being operated on environmentally clean technology. The stack emissions from the plant are controlled by ESP's. Bag Filters are installed at various material transfer points to clean the process and arrest the fugitive emissions. The boiler Ash collected in the pollution control equipment is used in the process of existing cement plants, thus it can be said that the utilization of raw material is being done at their cost. Since the system is operated on total recycle, there is no effect on the cost of production.

PART – H

ADDITIONAL MEASURES / INVESTMENTS PROPOSAL FOR ENVIRONMENT PROTECTION INCLUDING ABATEMENT OF POLLUTION

Green belt development and tree plantation is our ongoing process. Plantation has been carried out in an area of around 63.8 hectare with (Total land: 187.56 hc.)165311 trees, which is ~34 % of the total land of plant area.

PART – I

ANY OTHER PARTICULATES FOR IMPROVING THE QUALITY OF ENVIRONMENT.

1. We have full-fledged Environment Department with three separate cells, for monitoring, maintenance of pollution control equipment and Green Belt development.
2. Monitoring of stack emission and ambient air and water quality is being done regularly.
3. Maintenance department is doing regular checking and scheduled maintenance of all the pollution control devices.
4. Civil dept. taking care for of House keeping.
5. Horticulture Department is taking care of tree plantation and green belt development. Every year we are doing tree plantation.
6. Air cooled condensers has been installed at all the boilers for water conservation,
7. Waste water generated is reused in synthetic gypsum plant.

We are enclosing herewith following documents

- Annexure-1: Stack Emission monitoring report.
 - Annexure-2: Ambient Air Quality (PM10, PM2.5, SO2 and NO2) & Ambient Noise Level monitoring report
 - Annexure-3: STP treated water analysis report
-

Shree Cement Ltd; Ras
Captive Power Plant
Stack Emission Report (All values in mg/Nm³)
Year:- 2015-16

S. No.	Month	Boiler- I ESP	Boiler- II ESP	Boiler- III ESP	Boiler- IV ESP	Boiler- V ESP	Boiler- VI ESP	Boiler-VII ESP
1	Apr-15	NR*	NR*	28.0	26.0	27.0	27.0	NR*
2	May-15	NR*	NR*	27.0	25.0	26.0	25.0	NR*
3	Jun-15	30.0	NR*	28.0	26.0	28.0	29.0	NR*
4	Jul-15	24.0	29.0	NR*	27.0	25.0	26.0	27.0
5	Aug-15	32.0	28.0	NR*	26.0	22.0	21.0	27.0
6	Sep-15	32.0	25.0	NR*	32.0	23.0	28.0	30.0
7	Oct-15	NR*	22.0	25.0	27.0	27.0	26.0	29.0
8	Nov-15	NR*	NR*	NR*	21.0	23.0	24.0	25.0
9	Dec-15	-	18.0	22.0	21.0	28.0	27.0	26.0
10	Jan-16	-	21.0	18.0	22.0	24.0	21.0	19.0
11	Feb-16	-	15.0	NR*	22.0	12.0	23.0	25.0
12	Mar-16	-	15.0	NR*	19.1	12.0	34.3	25.0
Average		30	22	25	25	23	26	26

NR* Boiler not running

Annexure: 3

Shree Cement Ltd, Ras																									
Ambient Air Quality ($\mu\text{g}/\text{M}^3$) & Noise Level Monitoring Report For The Period Of April 2015 To Mar 2016																									
Common for Cement plant & Power plant																									
Year:-2015-2016																									
Location →	Plant Boundary Near Main Gate						Plant Boundary Near Mess						Plant Boundary towards Stacker & Reclaimer						Plant boundary towards village Khera & Jawangarh						
	AAQ in $\mu\text{g}/\text{M}^3$				Noise Level in dB(A)		AAQ in $\mu\text{g}/\text{M}^3$				Noise Level in dB(A)		AAQ in $\mu\text{g}/\text{M}^3$				Noise Level in dB(A)		AAQ in $\mu\text{g}/\text{M}^3$				Noise Level in dB(A)		
Parameter →	PM 2.5	PM-10	SO ₂	NO ₂	Day time	Night time	PM 2.5	PM 10	SO ₂	NO ₂	Day time	Night time	PM 2.5	PM 10	SO ₂	NO ₂	Day time	Night time	PM 2.5	PM 10	SO ₂	NO ₂	Day time	Night time	
Apr-15	24.	45.9	8.9	11.5	67.5	54.2	24.9	45.9	8.9	11.5	66.1	57.1	29.8	51.9	8.8	11.4	67.2	62	28.3	52.4	9.0	11.6	67.1	57.1	
May-15	23.	45.4	8.7	11.2	66.5	54.3	28.1	48.9	9.3	11.7	66.1	56	28.8	51.3	8.6	11.0	65.1	61	27.8	51.3	8.8	11.3	66.2	56.1	
Jun-15	23.	44.5	8.5	11.0	64.0	52.1	27.4	46.8	9.1	11.5	65.1	55.1	27.9	49.8	8.4	10.8	66.3	62	26.4	49.9	8.6	11.0	65.1	55.1	
Jul-15	23.	46.0	8.8	11.0	63.5	57.2	25.1	48.3	9.4	11.5	66.9	59.5	28.1	49.6	8.7	10.8	64.7	58.9	26.1	48.9	8.9	11.0	64.2	56.3	
Aug-15	23.	44.1	8.5	10.9	63.1	53.1	27.5	45.5	9.0	11.4	64.1	57.2	27.1	48.6	8.3	10.7	65.1	59	26.8	49.9	8.6	10.9	66	56	
Sep-15	22.	43.0	8.3	10.8	62.8	54.2	28.1	45.0	8.9	11.3	65.7	58.6	26.5	47.9	8.2	10.6	66.3	60.1	26.8	48.1	8.4	10.8	64.8	58.2	
Oct-15	23.	44.3	8.8	10.9	63.8	55.3	28.0	46.8	9.4	11.3	66.4	59.2	26.6	47.0	8.7	10.7	67.2	61.2	26.4	48.6	8.9	10.9	65.8	59.6	
Nov-15	24.	42.4	8.9	10.9	62.2	56.2	28.0	47.0	9.5	11.4	65.3	55.8	28.0	48.0	9.0	11.0	66.3	56.3	25.0	48.0	9.0	11.0	65.1	56.7	
Dec-15	24.	42.4	8.9	10.9	61.3	55.2	28.0	47.0	9.5	11.4	64.6	53.5	26.6	46.1	8.8	10.8	67.2	56.3	24.6	46.6	8.9	10.9	63.1	55.3	
Jan-16	25.	45.9	8.9	11.1	62.5	54.6	24.0	45.4	9.4	11.6	65.4	55.8	27.8	47.6	8.8	11.0	66.9	57.2	25.6	47.3	9.0	11.2	64.1	56.3	
Feb-16	24.	43.9	8.8	11.3	61.0	50.1	23.5	46.0	9.4	11.7	62.5	57.6	28.3	46.4	8.7	11.2	60.3	52.3	26.1	45.8	8.9	11.3	65.3	53.2	
Mar-16	24.	42.3	8.8	11.1	58.3	49.6	24.5	44.5	9.4	11.5	61.2	54.6	29.4	43.5	8.7	11.0	56.2	51.2	26.5	43.8	8.9	11.1	62.3	52.1	
Average	24.	44.2	8.7	11.0	63.0	53.8	26.4	46.4	9.3	11.5	65.0	56.7	27.9	48.1	8.6	10.9	64.9	58.1	26.3	48.4	8.8	11.1	64.9	56.0	

Annexure: 4

(STP Treated Water Quality, Year 2015-2016)														
S. No.	Parameter ↓	Apr-15	May-15	Jun-15	July-15	Aug-15	Sep-15	Oct-15	Nov-15	Dec-15	Jan-16	Feb-16	Mar-16	Avg.
1	pH	7.5	7.3	7.4	7.5	7.3	7.8	7.6	7.4	7.5	7.6	6.8	6.9	7.4
2	Suspended Solids	60.1	59.1	58.2	59.7	59.1	52.4	54.2	55.4	57.0	56.8	58.1	59.1	57.4
3	Oil and Grease	0.3	0.2	0.1	0.4	0.1	0.2	0.3	0.2	0.3	0.4	0.2	0.1	0.2
4	BOD 3days 27°C	17.1	16.5	15.5	14.8	14.2	12.3	11.3	12.1	13.8	12.8	11.8	11.5	13.6
5	COD	71.2	70.1	69.1	70.2	70.2	67.9	68.4	72.3	71.3	72.4	80.1	75.3	71.5